



EUROPEAN
REGIONAL
DEVELOPMENT
FUND




Retrofitting ozonation into existing plants

Robert Sehlén
Tekniska verken i Linköping


March 14th 2019

Retrofitting ozonation into existing plants

System – ozone reactor and MBBR



Comparison pilot and full scale studies



Retrofitting ozonation into existing plants

Ozone production capacity – Risc matrix

Pilot study


Pilot study	0,47 mg O ₃ /mg DOC, N corr					
	5 mg O ₃ /L	MEC (µg/L)	NOEC (µg/L)	Assessment factor	Dilution recipient	MEC/PNEC quota
Oxazepam	0,1		1,8	1000	27	2,058
Metoprolol	0,25		1	50	27	0,463
Trimethoprim	0,001		0,29	100	27	0,013
Ibuprofen	0,14		10	10	27	0,005
Ciprofloxacin	0,009		1,2	10	27	0,003
Atenolol	0		1000	100	27	0,000
Citalopram	0		105	100	27	0,000
Diclofenac	0		0,5	10	27	0,000
Propranolol	0		0,5	50	27	0,000
Sulfamethoxazole	0		250	100	27	<0,01

Full scale


- High assessment factor for Oxazepam
- Metoprolol below high risc level: 0.73 mg O₃/mg DOC, N corr (~10 mg O₃/L)

Large-scale study	0,58 mg O ₃ /mg DOC, N corr					
	9 mg O ₃ /L	MEC (µg/L)	NOEC (µg/L)	Assessment factor	Dilution recipient	MEC/PNEC quota
Oxazepam	0,16		1,8	1000	27	3,292
Metoprolol	0,76		1	50	27	1,407
Trimethoprim	0,01		0,29	100	27	0,128
Diclofenac	0,11		0,5	10	27	0,081
Citalopram	0,04		105	100	27	0,001
Atenolol	0,28		1000	100	27	0,001
Sulfamethoxazole	0,01		250	100	27	0,000
Propranolol	0		0,5	50	27	0,000
Ciprofloxacin	<10d		1,2	10	27	0,000
Ibuprofen	<10d		10	10	27	0,000

Designing a plug-flow reactor, CFD-simulation



Residence Time Distribution and plug-flow evaluation



$$T_{10} = 19 \text{ min} \quad T_{90} = 46 \text{ min} \text{ at } 2000 \text{ m}^3/\text{h}$$

$$T_{TDT} = \frac{V}{Q} = 16.7 \text{ min}$$

- Baffle factor BF: $\frac{T_{10}}{T_{TDT}} = 1.13$ (1.0 for plug flow)
- Morril index MI: $\frac{T_{90}}{T_{10}} = 2.42$ (1.0 for plug flow)


Things to bear in mind when specifying the design

- The current process design
Any obvious choice where to retrofit the ozone plant?
Existing post treatment e.g. sandfilter or MBBR
- Particles in bio treated water
Blocking equipment
Blocking filters
Sludge → Foaming. By-passing the plant?
- Freezing problems during stops

Retrofitting ozonation into existing plants

Things to bear in mind when specifying the design

- Cooling
 - Biofilm growth in HEX
 - Increased temp -> incr ozone degradation -> incr energy consumption
- Power Capacity
- Specific energy demand



Working environment

- Ozone
Very powerful oxidizing agent
- Oxygen
Oxygen reacts explosively with fats
Asphalt contains bitumen → Gravel around the LOX tank
- Noise 1400 Hz
- Magnetic field
- Ozone resistant materials
Stainless steel
PTFE
No fat!!
- **All this can be dealt with preventive measures and good practices**